

CERTIFICATE OF COMPLIANCE

Number: 5046/C444B

Dated: 3 April 1996

Issued to: Blakley Electrics Limited


Apparatus: FLK Transformer

This is to certify that a sample of the equipment defined above has been type tested by ERA Technology Limited and found to comply with the following requirements:

BS EN 60529 : 1992 "Degrees of protection provided by enclosures (IP Code)" for a Degree of Protection IP54


Full details are given in ERA Report No: 5046/444 dated April 1996

Certificate prepared by:



G D Lightfoot
Technician
Explosion and Fire Hazards

Certificate approved by:



for **G R Oliver**
Manager
Industrial Products Department

ERA Technology Limited
Industrial Products Department
Cleeve Road Leatherhead Surrey KT22 7SA England
Telephone : +44 (0) 1372 367000
Fax: +44 (0) 1372 367099
Telex: 264045