

# Certificate of Compliance

Issued to: **Blakley Electrics Limited**

Apparatus: **LUL Switchboard**

Model: **1 off A7290099**

No. of Samples Tested: **One**

Relevant Specification used as Basis of Tests: **BS EN 60529: 1992 Inc Amendments 1 and 2 to IP55 category 2**

This is to certify that, on the basis of the tests undertaken, the above item was considered to comply with the severity of the above standard. For specific details of the tests and justification for Category 2 dust test see Intertek Report No 05017323 Issue 1 dated July 2005.

Signed: Signature.....  
A Colgate  
Engineer

Signed: Signature.....  
A T Austin  
Head Of Department

Date of issue: July 2005



Blakley Electrics Limited  
Marsh Lane  
Ware  
Hertfordshire  
SG12 9QC

Serial No: 05 4448  
Reference No: 05017323B