

Intertek**ETL SEMKO**

Certificate of Compliance


Issued to:**Blakley Electrics****Item Tested:****TDC Electrical Enclosure****Model:****Drg No. C3965****No. of Samples Tested:****1 off****Relevant Specification
used as Basis of Tests:****BS EN 60529: 1992 Inc
Amendments 1 and 2 for a rating
of IP55 (Category 2)**

This is to certify that, on the basis of the tests undertaken, the above items were considered to comply with the severity of the above standards. For specific details of the tests see Intertek Report No 08034858 Issue 1 dated Aug 2008.

Signature


**A Hurford
Engineer**

Signature


**A Smart
Principal Engineer**

Date of issue: August 2008

**Blakley Electrics
Marsh Lane
Ware
Hertfordshire
SG12 9QQ****Serial No: 08 5963
Reference No: 08034858****Intertek Testing & Certification Ltd**Intertek House, Cleeve Road, Leatherhead, Surrey KT22 7SB
Telephone: +44 (0)1372 370900 Fax: +44 (0)1372 370999 Web: www.uk.intertek-etlsemko.com

Registered No. 3272281 Registered Office: 25 Savile Row, London W1S 2ES

For Terms & Conditions please see reverse