



- LOUVRE BLANK
- WALL OR FLOOR MOUNTING BRACKETS.

TL*/A ASSEMBLY


MAX.RATING: –
0.5kVA SINGLE PHASE
WITH NO EXTERNAL MCBs OR SOCKETS.
REFER TO ENGINEERING FOR MAX.RATING
WHEN MCBs OR SOCKETS ARE REQUIRED.



—LOUVRE BLANK
—WALL OR FLOOR
MOUNTING BRACKETS.

TL*/B ASSEMBLY

MAX.RATING: –
2kVA SINGLE PHASE
WITH EXTERNAL MCBs OR SOCKETS.




CUSTOMER
INFORMATION
COPY

GENERAL NOTES

- 1) TLP/A AND TLP/B – LID TYPE HANDLES AS ABOVE, NO EXTERNAL BRACKETS SUPPLIED.
- 2) TLW/A AND TLW/B – SUPPLIED WITH A PAIR OF 'BOLT ON' BRACKETS AS SHOWN ABOVE,
THESE CAN BE REMOVED AND REFITTED AS FLOOR MOUNTING BRACKETS.
- 3) TL*/A AND TL*/B – ALL UNITS CAN BE SUPPLIED WITH THE LOUVRES BLANKED OFF,
IP RATINGS AS FOLLOWS:–
LOUVRES – IP23
LOUVRES BLANKED – IP44
IF MCBs FITTED WITHOUT WINDOWS – IP21
- 4) LABELS: NAME/RATING,WARNING AND OTHER LABELS POSITIONED AS REQUIRED
- 5) ADDITIONAL EQUIPMENT MOUNTED AS SPECIFIED ON WORKS ORDER

THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF BLAKLEY ELECTRICS AND MUST NOT, WITHOUT THEIR WRITTEN CONSENT, BE PASSED ON, COPIED, OR USED FOR ANY OTHER PURPOSE.

REV:	A																							
EDR:	6736																							
UNLESS OTHERWISE STATED:— ALL DIMENSIONS IN MM. TOLERANCES TO H30052 FIXING STANDARD TO H30051 WIRING STANDARD TO H20051 WELDING STANDARD TO QAI 61.										<div>MATERIAL</div> <div>MILD STEEL</div> <div>SIZE</div>														
<div></div>										REF. STANDARD					COPY ISSUED									
										ORIGINAL SCALE 1:4					<div>BLAKLEY</div> <div>ELECTRICS LIMITED</div>									
DO NOT SCALE THIS DRAWING. IF IN DOUBT, ASK										DATE. 14.12.15														
TITLE 'TL' TRANSFORMERS GENERAL ASSEMBLY										DRN. B.JONES					DRAWING No.					A				
										CHKD.					C13966									
										APPD.					SHEET 1 OF 1									