

TOP FACE LEFT BLANK TO BE CUT/DRILLED TO SUIT UPON INSTALLATION

HASP FITTED TO TOP & BOTTOM OF DOOR

VIEW ON TOP

OUTPUT CONNECTIONS C/W M16 FIXINGS

NOTES:

- DESIGN GENERALLY IN-LINE WITH SSE REQUIREMENTS DRAWING HO/65/037.
- INCOMER N-E LINK INSTALLED BY DEFAULT (MAY REQUIRE REMOVAL TO SUIT SITE EARTHING SYSTEM).
- TAILS TO METERING FUSES ARE LONG ENOUGH TO TERMINATE ON EITHER SIDE OF THE CT LINKS.
- CT LINKS ARE SLEEVED IN THE APPROPRIATE PHASE COLOUR.
- CABLING FROM THE METER TO THE FUSES ENTER VIA THE TOP OF THE CARRIER (COMPLETED BY OTHERS).
- METERING FUSE TYPE IS 'NS' (F1) PATTERN, NEUTRAL LINK IS 'SS' (E1) PATTERN.
- OVERALL ASSEMBLY IP: IP44.
- OVERALL APPROXIMATE WEIGHT OF ASSEMBLY: 180KG.
- SPLIT GLAND PLATES, WOODEN CLAMPS AND REMOVABLE SECTION IN THE ENCLOSURE, ENABLE EASIER INPUT CABLE INSTALLATION.
- THE ASSEMBLY SHOWN IS FOR WALL/BACKBOARD MOUNTING (COMPLETED BY OTHERS), A (FREESTANDING) STAND ASSEMBLY IS AVAILABLE (SOLD SEPARATELY).

RATING PLATE

METERING FUSES

SLEEVED CT LINK (CTs SUPPLIED BY OTHERS)

IN 4 POSNs (EACH SIDE) WALL MOUNTING POINTS M8 CLEARANCE

INCOMER BARS ACCEPT BOTH 4 HOLE AND 2 HOLE CABLE LUGS TO SSE DOCUMENT SP-PS-315 (M10 & M12 FIXINGS PROVIDED)

SPLIT CABLE LUG SHOWN FOR REF. ONLY (NOT SUPPLIED WITH THE CTC ASSEMBLY)

WOODEN CABLE CLAMPS

END FRAME (M12) EARTH PROVISION

605.0 REF.
513.0


REMOVABLE SECTION 440.0mm TO AID CABLE INSTALLATION

IN 4 POSNs (M8) MOUNTING POINTS FOR GROUND MOUNTING OR SECURING TO THE OPTIONAL STAND ASSEMBLY

VIEW ON FRONT

VIEW ON L.H.S (INC. SPLIT LUG, CTs & BARS SHOWN FOR REF. ONLY)

VIEW ON R.H.S (INC. SPLIT LUG, CTs & BARS SHOWN FOR REF. ONLY)



VIEW ON UNDERSIDE

CUSTOMER INFORMATION COPY

REV: A	EDR: 8331	MATERIAL	SIZE
UNLESS OTHERWISE STATED:- ALL DIMENSIONS IN MM TOLERANCES TO H30052		REF: S031338A	COPY ISSUED 13 Jul 2022
FIXING STANDARD TO H30051 WIRING STANDARD TO H20051 WELDING STANDARD TO QAI 061.		ORIGINAL SCALE 1:6	DATE: 12.07.22
DO NOT SCALE THIS DRAWING. IF IN DOUBT, ASK			
TITLE: GENERAL ASSY. FOR CTC/800/SR/037 CT CHAMBER			
DRN: B.W.	CHKD.	DRAWING No. A36265	REVISION A
APPD.			