

SELF ADHESIVE CIRCUIT DESIGNATION LABEL SUPPLIED WITH FUSEBANK TO BE FIXED TO BACK OF DOOR ADJACENT TO FUSEBANK.

IDENT LABEL (M4 FIXINGS) (LABEL PROVIDED BY OTHERS)

PADLOCK HASP

1 OFF FUSEBANK 63A 6 WAY

KEY LOCK


NEUTRAL BAR

EARTH BAR




DOCUMENT POCKET ON REAR OF DOOR

M10 EXTERNAL EARTH STUD

DANGER ELECTRICITY



VIEW SHOWING RATING PLATE & LABEL POSITIONS ON THE DOOR



REV: A	EDR: 6980										
UNLESS OTHERWISE STATED:- ALL DIMENSIONS IN MM. TOLERANCES TO H30052 FIXING STANDARD TO H30051 WIRING STANDARD TO H20051 WELDING STANDARD TO QAI 61.						MATERIAL		SIZE			
DO NOT SCALE THIS DRAWING. IF IN DOUBT, ASK						REF. S060950		COPY ISSUED			
TITLE <b>GENERAL ASSEMBLY</b> <b>FB/1N/63/6W</b> <b>SELLAFIELD SITES</b>						ORIGINAL SCALE 1:6		<b>BLAKLEY</b> ELECTRICS LIMITED			
						DATE. 22.11.16					
						DRN. JET		A7291549		A	
						CHKD.		SHEET 1 OF 1			
						APPD.					

THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF BLAKLEY ELECTRICS AND MUST NOT, WITHOUT THEIR WRITTEN CONSENT, BE PASSED ON, COPIED, OR USED FOR ANY OTHER PURPOSE.