

INCOMING
CABLE TERMINATIONS
MAX CABLE SIZE 4MM²

SECONDARY FUSE
PROTECTION

2 No. OUTGOING
CABLE TERMINATIONS
MAX CABLE SIZE 4MM²

3 No. 20.6Ø
KNOCK-OUTS
BOTH SIDES

INCOMING
EARTH STUD

TRANSFORMER
AUTO-WOUND
1500VA 230-115V

REAR VIEW

SIDE VIEW

FRONT VIEW


BASE VIEW

NOTES.

BASED ON ATLW/1.5/F (A7050312) WITH THE FOLLOWING CHANGES:

- a) WALL/FLOOR MOUNTING BRACKETS NOT REQUIRED.
- b) ENCLOSURE FIXINGS CHANGED FROM HEXAGON HEAD BOLTS TO BUTTON HEAD HEXAGON SOCKET SCREWS.
- c) COLOUR: WHITE.

THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF BLAKLEY ELECTRICS AND MUST NOT WITHOUT THEIR WRITTEN CONSENT BE PASSED ON, COPIED, OR USED FOR ANY OTHER PURPOSE. THIS COPY IS UNCONTROLLED UNLESS OTHERWISE MARKED.

REV:	-								
EDR:	-								
UNLESS OTHERWISE STATED:- ALL DIMENSIONS IN MM. TOLERANCES TO H30052 FIXING STANDARD TO H30051 WIRING STANDARD TO H20051 WELDING STANDARD TO QAI 61.						MATERIAL 1.2mm MILD STEEL U.O.S.		SIZE	
DO NOT SCALE THIS DRAWING. IF IN DOUBT, ASK						REF. STANDARD		COPY ISSUED	
						ORIGINAL SCALE 1:4			
TITLE GENERAL ASSEMBLY ATLW/1.5/F						DATE. 22.06.2006			
						DRN. B.JONES		REVISION	
						CHKD.			
						APPD.		SHEET 1 OF 1	